

CATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

No.: 2020312303000422

EXPO Technologies Limited Applicant

Unit 2, The Summit, Hanworth Road, Sunbury on Thames Surrey **Address**

TW16 5DB, United Kingdom

EXPO Technologies Limited Manufacturer

Unit 2. The Summit, Hanworth Road, Sunbury on Thames Surrey **Address**

TW16 5DB, United Kingdom

EXPO Technologies Limited Production Factory

Unit 2, The Summit, Hanworth Road, Sunbury on Thames Surrey **Production Address**

TW16 5DB, United Kingdom

Product Minipurge Interface Units MIU/e1, MIU/e2, MIU/e1/MO Model/Type

Ex e IIC T5/T4 Gb, Ex tD A21 IP66 T100°C Ex marking

GB3836.1-2010, GB3836.3-2010, GB12476.1-2013, **Reference Standards**

GB12476.5-2013

Type Test + Initial Factory Inspection + Post-Certification Surveillance Certification mode

The product(s) is verified and certified according to CNCA-C23-01: 2019 China Compulsory Certification Implementation Rule on Explosion Protected Electrical Product and CNEX-C2301-2019 Guideline of China Compulsory Certification Implementation Rule on Explosion Protected Electrical Product.

See Annex for the detailed product information (1 page).

Valid to: 2025-11-03 Issued on: 2020-11-04

The validity of this certificate is maintained through the regular supervision of the issuing authority during the validity period.

Where any discrepancy arises between the English translation and the original Chinese version, the Chinese version shall prevail.





Nanyang Explosion Protected Electrical Apparatus Research Institute Co., Ltd.



http://www.ccc-cnex.com ccc.china-ex.com

P.C.: 473008 Add: No. 20, North Zhongjing Road, Nanyang, Henan, P. R. China

Tel: 0377-63239734 Email: ccc@cn-ex.com



OR CHINA COMPULSORY PRODUCT CERTIFICATION

(Annex)

No.: 2020312303000422

Page 1 of 1

Product information:

This certificate covers the following models:

- MIU/e1, MIU/e2, MIU/e1/MO

Parameters:

MIU/e1、MIU/e2: 7A, 400V, IP66

MIU/e1/MO: 2A, 400V, IP66

Ex marking:

MIU/e1, MIU/e2: Ex e IIC T5/T4 Gb, Ex tD A21 IP66 T100°C (Ta: -20°C...+55/60°C)

MIU/e1/MO: Ex e IIC T5 Gb, Ex tD A21 IP66 T100°C (Ta: -20°C...+55°C)

- Producers should organize production in accordance with the technical documents approved by the certification body.

- Specific conditions of safety use: 2.
 - Cable glands, breathers, drains and plugs shall be appropriately certified types, suitable for the cable and conditions for use and installed in accordance with their manufacturers' instructions. They shall maintain the IP66 rating of the enclosure.
 - See instruction for other information.
- Certificate related report(s):
 - Type test report: CQST2009C580
 - Factory inspection report: CN2020Q010175

Certificate change information: None

Issued on: 2020-11-04

Director:



Nanyang Explosion Protected Electrical Apparatus Research Institute Co., Ltd.



P.C.: 473008